



City of Danville, Virginia

PO Box 3300
Danville, VA 24543

427 Patton Street, Rm 304
Danville, VA 24541

J. Gary Via, CPPO
Director of Purchasing
e-mail: viajg@danvilleva.gov

Phone: (434) 799-6528
Fax: (434) 799-5102
e-mail: purchasing@danvilleva.gov

**Charles Harris (Financial Services) Building
Roof Replacement Project
IFB No. 19-20-013
Addendum No. 1
August 8, 2019**

NOTE: Bidder shall acknowledge receipt of Addendum No. 1 on the Bid Proposal Form.

1. Contract Drawings A1.01

- a. Delete reference to Keyed Note No. 6 Air Handling Unit (AHU) and insert the following:
 - The owner will remove the AHU and relocate it to the upper roof, provide a new curb and replace the ductwork and electrical.
 - Roofing contractor to remove the existing steel frame and pipe supports.
 - Roofing contractor to install and flash the new AHU curb per roof manufacturer's recommendations.
- b. Owner will remove and reinstall existing cameras and camera cabling.

2. Specifications Section 075323 "EPDM Roofing" Paragraph 2.3 Roof Insulation

- a. Provide ASTM C 1289, Type II, Class I, Grade 2, glass fiber mat fiber on both sides, 20 PSI polyisocyanurate board insulation complying with FM-4450.

END OF ADDENDUM NO. 1

J. Gary Via, Director of Purchasing

Company Name: _____ Signature: _____

Address: _____ Signature: _____

(Printed)

City State Zip Code Title: _____

Date: _____ e-mail address: _____

Phone No: _____ Fax No: _____